

شروط ومواصفات لوحات أعضاء جماعة الإرشادية للمداخل الرئيسية ومناطق التجمع في مواقع الأعضاء ومتطلباتها.

1. لوحة مدخل أعضاء جماعة:

يجب على كل عضو من أعضاء جماعة أن يعين مدخلين مختلفين لمنشأته (إذا كان ذلك ممكن) للاستخدام في الحالة الطارئة عند استدعاء أعضاء جماعة للمساعدة - واحد مدخل رئيسي والثاني مدخل بديل في الحالات الطارئة فقط في حالة عدم القدرة على استخدام المدخل الرئيسي للمنشأة. كما يجب على العضو القيام بعمل لوحة إرشادية يكتب عليها (باللغة العربية والإنجليزية) "مدخل أعضاء جماعة" الرئيسي" ولوحة ثانية مكتوب عليها "مدخل أعضاء جماعة" البديل) ومقاسها 200 سم × 100 سم (انظر الشكل رقم 1-2 الملحق رقم 11(ب)) وتطلى باللون الأخضر العاكس للضوء من أجل رؤيتها بوضوح في الليل وتكون الكتابة باللون الأبيض العاكس للضوء، وتكون الحروف ذو شكل متناسق مع حجم اللوحة وبارزة لإمكانية قراءتها بوضوح من بعد، كما أنه يجب تثبيت اللوحة الأولى على السياج من الخارج عند مدخل أعضاء جماعة الرئيسي للمنشأة واللوحة الثانية على سياج المدخل البديل للمنشأة. تطل

2. لوحة منطقة تجمع أعضاء جماعة:

تتبع نفس المواصفات الموضح أعلاه لعمل لوحة خاصة مكتوب عليها (باللغة العربية والإنجليزية) "منطقة تجمع أعضاء جماعة" ويكون مقاسها 200 سم × 100 سم وارتفاعها عن الأرض لا يقل عن مترين (انظر الشكل رقم 3). وتكون الحروف ذو شكل متناسق مع حجم اللوحة وبارزة لإمكانية قراءتها بوضوح من بعد. يجب تثبيت اللوحة في موقع بعيد عن المباني والمنشآت الصناعية ولكن داخل سياج العضو ويكون الموقع مخصص لاستخدام أعضاء جماعة فقط المطلوبين للمساعدة من قبل العضو المتضرر.

3. متطلبات موقع منطقة التجمع:

يجب أن تتسع "منطقة تجمع أعضاء جماعة" لعدد من سيارات الإطفاء والإسعاف لا يقل عن 8 إلى 10 سيارات ويفضل أن تكون مجهزة بإنارة. كما يجب مراعاة اتجاه الرياح السائدة عند اختيار موقع منطقة التجمع لسلامة الأعضاء ومعداتهم المتواجدين فيها. كذلك يجب على كل عضو تعيين شخص في مستوى المسؤولية ومعرف بسترة خاصة بترقالية اللون عاكسة للضوء ومكتوب عليها "مدير منطقة التجمع" لاستقبال وإرشاد أعضاء جماعة القادمين للمساعدة وتنظيم الحركة في منطقة التجمع. ويجب توفير مياه للشرب وبعض المشروبات الباردة الأخرى للأعضاء المتواجدين في هذه المنطقة.

REQUIREMENT & SPECS OF JAMA'A MEMBERS ENTRY AND STAGING AREA SIGNS

1) JAMA'A Members Entrances Signs:

Every JAMA'A member shall pre-identify two entry points available for use by responding JAMA'A members' equipment. The entry points should be classified as "**JAMA'A Primary Entrance**" and "**JAMA'A Alternate Entrance**". The Alternate Entrance is to be used when conditions negate the utilization of the Primary Entry location.

The plant primary entrance should be clearly identified by a sign 200cm x 100cm painted fluorescent green with white reflective lettering and with the appropriate information both in Arabic and English for responding JAMA'A equipment (see fig. 1). The Arabic letters should be on top of the English letters. The size of the letters should be symmetrical to the size of the signboard and should be large enough so it can be clearly read from a distance and during darkness. The Primary Entrance sign can be affixed on the plant security fence from out side on the Main Gate Entrance. The second sign can be affixed on the alternate entrance fence gate.

2) JAMA'A Members Staging Area Sign:

The "**JAMA'A Members Staging Area**" should be clearly identified by a sign 200cm x 100cm painted fluorescent green with white reflective lettering and with the appropriate information both in Arabic and English for responding JAMA'A equipment (see fig. 2). The Arabic letters should be on top of the English letters. The sign should be readable during darkness and its height should not be less than 2 meters from the ground. The size of the letters should be symmetrical to the size of the signboard and should be large enough so it can be clearly read from a distance.

3) JAMA'A Staging Area Requirements:

Each member requesting JAMA'A assistance should assign a responsible individual at its "**JAMA'A Members Staging Area**" to direct and guide incoming JAMA'A equipment to the Staging Area. This individual should be identified by a fluorescent orange reflective vest marked in white letters "**JAMA'A Staging Manager**" in both Arabic and English. Drinking water and other refreshments should be made available by the requesting member at the Staging Area for the responding members.

Also JAMA'A Members Staging Area should be large enough to easily accommodate at least 8-10 of various size Emergency Vehicles dispatched by JAMA'A members to the requesting member and should be well lit at night and darkness.

مقاسات لوحات المداخل ومناطق التجمع في مواقع أعضاء
"جماعة"



(الشكل 1)



(الشكل 2)



(الشكل 3)

الملحق رقم 11 (ب)

Wordings and sizes of JAMA'A Members Primary and Alternate Entrance Signs and Staging Area Signs:



(Figure 1)



(Figure 2)



(Figure 3)